

PROPYLENE GLYCOL FREEZE PROTECTION AND BURST PROTECTION MIX PERCENTAGES

CELSIUS:	FAHRENHEIT:	FREEZE PROTECTION MIX PERCENTAGE:	BURST PROTECTION MIX PERCENTAGE:
-51.1	-60	63%	
-48.3	-55	61%	
-45.6	-50	60%	40%
-42.8	-45	58%	
-40.0	-40	57%	35%
-37.2	-35	54%	
-34.4	-30	53%	33%
-31.7	-25	50%	
-28.9	-20	49%	30%
-26.1	-15	46%	
-23.3	-10	43%	28%
-20.6	-5	41%	
-17.8	0	38%	24%
-15.0	5	34%	
-12.2	10	30%	20%
-9.4	15	25%	
-6.7	20	19%	12%
-3.9	25	12%	
-1.1	30	9%	
0.0	32	0%	

Recommended mix percentage for a typical indoor radiant heating system is 30% glycol. Do not exceed 50% glycol.